

NEEDS, CHALLENGES AND APPROACHES FOR NEW SERVICE LIFE ESTIMATION MODELS FOR PV MODULES- RESULTS FROM IEA-PVPS-TASK 13 SUBTASK 1.4

Karl-Anders Weiß^{1*}, Ismail Kaaya¹, Gernot Oreski², Laura S. Bruckman³,
Roger H. French³, Tadanori Tanahashi⁴

¹ Fraunhofer ISE, Heidenhofstr. 2, 79110 Freiburg, Germany

Corresponding author: karl-anders.weiss@ise.fraunhofer.de, T: +49 761 4588-5474

² PCCL Polymer Competence Center Leoben, Roseggerstraße 12, 8700 Leoben, Austria

³ Case Western Reserve University, Cleveland, USA

⁴ National Institute of Advanced Industrial Science and Technology (AIST), Koriyama, Japan

ABSTRACT: The economic success of photovoltaic (PV) power plants depends crucially on the lifetime energy yield. The degradation effect and the total lifetime directly influence the produced electricity and therefore the cash flow. In most cases, lifetimes and degradation rates, which are used for the estimation of plant behaviour, are nowadays still not system specific, but based instead on average values of evaluations of older systems or data sheets. So, these values unfortunately have no direct correlation with the specific components of the respective PV system. Also, the mathematical models used for calculated power output typically expect linear degradation rates which are not found in real degradation processes found in the field.

Activity 1.4 of the IEA PVPS Task 13 developed an overview on service life prediction and degradation modelling of PV modules since they are the major component of PV systems causing degradation effects and for other components no comparable scientific data is available.

Keywords: PV Module, Reliability, Degradation, Modelling

1 INTRODUCTION

The economic success and environmental impact of photovoltaic (PV) power plants depends crucially on the degradation and service life of the PV modules and other components of the PV power plants. The behaviour of PV modules is especially relevant since they typically show gradual degradation effects over time. The useful service lifetime and degradation of PV modules directly influences the lifetime yield of electricity, and therefore, the levelized cost of the electricity (LCOE) produced [1]. Degradation and service life are influenced not only by the materials used and the quality of module manufacturing, but also by local environmental effects that dictate the exposure conditions of the PV modules. Therefore, the lifetime and degradation of PV modules cannot be determined easily and are not valid for all locations and applications. Since both are dependent on local and operational conditions, the prediction of service lifetime from PV module degradation rates must be taken into consideration all of these factors and incorporate them into mathematical models.

2 PREPARING THE MANUSCRIPT

This report introduces the influencing factors for service life and degradation of PV modules and components as well as the modelling of degradation effects and service life prediction. It describes relevant stresses and load effects in section 3 and different modelling approaches, as well as models which have shown to fulfill the requirements of PV stakeholders in section 4. The descriptions are written in a way to address the needs of readers from all stakeholder groups, so on one hand people with no background in mathematical modelling who are interested in the influencing factors, potential of service life prediction, and interpretation of given data, as well as experts in reliability and degradation modelling. The chapters therefore briefly describe the approaches and

background as well as examples and list relevant literature for further reading.

Since the content of the report would exceed the possibilities of such a conference paper, only the executive summary is presented in the following. The readers are encouraged to download the full report which is available on the IEA PVPS Task 13 website.

3 EXECUTIVE SUMMARY

The economic success of photovoltaic (PV) power plants depends crucially on their lifetime energy yield. Degradation effects and the total lifetime directly influence the produced electricity and therefore the cash flow, which also impacts the levelized costs of energy (LCOE) and therefore the profitability of the power plant. In most cases, the lifetimes and degradation rates that are used to estimate the system performance are not system-specific, but are based on average values from the evaluations of older systems or data sheets. So, these values unfortunately have no direct correlation with the specific components of the specific PV system, nor the operational and climatic conditions at the specific location. Also, the mathematical models used for calculating the expected power output typically expect linear degradation rates which are not in line with real degradation processes found in the field, which are typically non-linear.

This report gives an overview on empirical degradation modelling and service life prediction of PV modules since they are the major components of PV systems that are subject to the effects of degradation. For other components, no comparable scientific data is available. The structure of the document addresses different stakeholders with different backgrounds. Chapter 1 begins with a short introduction including a condensed overview of the state of the art.

Chapter 2 follows with the definition of relevant terms and definitions. Since especially in discussions on lifetime and degradation different terms are not used

coherently in industry or science, the authors try to improve the situation with this dedicated glossary. In addition, the extremely relevant term “end-of-life” is discussed with different definitions, depending on the point of view and perspective of the user and the typical factors impacting the PV module or PV system. For this “end-of-life” term, no definition which is generally applicable in all situations can be given. Since the definition is crucial for the calculated service life, yield, and all related parameters, through to LCOE it is important to be aware of this when evaluating power plants and PV investments.

Climatic factors play a major role in degradation and are by nature location specific. It is precondition for the creation of meaningful service life prediction or degradation data to know about the relevant (climatic) stressors. Therefore Chapter 3 introduces the different relevant climatic stressors as well as classification schemes and methodologies to handle and analyse them. The chapter also describes differences and relations of the so-called macroclimatic stressors, describing the climatic conditions in the ambience of the modules, and the situation at material level, the so called micro-climatic stressors. The latter describes the relevant parameters for degradation processes and so also the mathematical models addressing module degradation and service life prediction. The ambient macro-climatic conditions at specific locations can be estimated using data for the climatic regions or adapted climatic maps and so be classified using climatic classification schemes which exist also specified for PV purpose like the Köppen-Geiger PV scheme. For the determination of microclimatic loads - which are typically input parameters for degradation models, further calculations are necessary. The report presents possible ways to determine the necessary data for the most important micro-climatic parameters which are temperature and humidity. This data is also very important for the definition of accelerated tests, which can deliver module specific parameters for the service life and degradation prediction. Chapter 3 also describes basic accelerated ageing tests, as described in the respective IEC standards, and how they can support degradation and service life prediction and modelling as well as their limitations.

Chapter 4 addresses general degradation and service-life modelling approaches including related issues. It starts in section 4.1 with general issues of empirical modelling one has to be aware of when working on mathematical modelling solutions for service life and degradation prediction and interpreting results. There are very different approaches for empirical modelling of the lifetime performance prediction and service life of products such as PV modules empirical statistical modelling, and empirical physical modelling. Physical empirical models are those that utilize analytic or numerical forms to represent the fundamental physics and chemistry of the phenomena. Statistical models, often referred to as data driven models, use mathematical forms which are able to fit the (measured) data without direct relation to physical or chemical processes. Both approaches use empirical (measured) data to determinate parameters which can be used for predicting future behaviour.

Section 4.2 introduces on one hand models for specific degradation modes or phenomena of modules (e.g., backsheet or cell cracking or electrochemical

corrosion). On the other hand, modelling approaches for degradation effects of components and materials are presented. A special focus is here on degradation of polymeric materials since these materials are known to be sensitive to degradation effects caused by typical climatic stressors like high temperature, humidity and UV radiation. The modelling approaches using predictive models and inferential mechanistic models are presented using polyethylene terephthalate (PET) degradation as catchable example. It is shown that different modelling approaches are necessary to describe all degradation effects. Weak points of modules can be identified, and focussed optimization of products can be supported.

Performance degradation models are addressed in Section 4.3 which are the core models for the prediction of degradation of modules over time for specific types and locations. Combined with defined end-of-life conditions, these models can be used for service life prediction. Different approaches which have been specifically developed for PV modules are presented. Starting with an approach focusing on physical and chemical processes and the specific application. An approach to develop performance loss rate (PLR) models following the statistical methodology is presented as well including the processes to determine the relevant parameters from field data.

The modelling approaches are presented including the methodological approach to the problem the used input data, and parameters related to specific module types or local climatic conditions, down to calculations of degradation rates over time or remaining useful lifetime (RUL) or total expected lifetime.

The latest scientific work shows that service lifetime and degradation models for PV modules are of specific use if they combine different modelling approaches and include know-how and modelling parameters of the most relevant degradation effects. Such models can differentiate between the behaviour of different module types and to include the situation at different service locations. For some modules, it is also necessary to use multi-step modelling approaches to enable meaningful results.

Advanced approaches of data analysis and modelling also enable the determination of degradation signatures which can be related to specific degradation effects. This approach is expected to be very helpful in future work to identify failures based on operational data.

Since uncertainties of input parameters can have significant impact on the results but are often not totally avoidable, these topics are addressed in Chapter 4.3.

4 ACKNOWLEDGEMENT

This paper is supported by the German Federal Ministry for Economic Affairs and Energy (BMWi) under contract no. 0324304A and 0324304B.